

PROFORMA FOR SAFE DRINKING WATER CERTIFICATE

No. 529

Date:- 16/02/26

It is certified that an inspection team headed by Chemist. DLWTL, P.H Division Jamui from P.H Division jamui inspected the T R Narayan Heritage School Located at Swami Vivekanand Colony, near Power Sub Station, Mahisauri, Jamui - 811307 at- Bihar on 14-02-2026 and found that the T R Narayan Heritage School Located at Swami Vivekanand Colony, near Power Sub Station, Mahisauri, Jamui - 811307 has safe drinking water facilities for the students and members of staff of the institution as per norms prescribed by Central/State/U.T. Govt.

The above is valid for a period of six month

Prin
16.02.26

Signature with seal. **Executive Engineer**
P.H. Division, Jamui

Name: Prince Kumar

Designation: Executive Engineer

Name & Address of the Office/Department

P.H Division, Jamui

TR 16/02/2026

To
Principal
T R Narayan Heritage School
Swami Vivekanand Colony,
near Power Sub Station, Mahisauri,
Jamui - 811307

District Name :- Jamui

Government of Bihar
Public Health Engineering Department
Division Name :- Public Health Division, Jamui

Sample Collected by-SCHOOL STAFF

Water Quality Test Report

Date of Sampling:-14.02.2026

Physico-Chemical and Bacteriological Parameters																		
				PH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alkali.	NO3	F	T.Coli	Source of Water	Remarks	
Unit				-	NTU	ymho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100 ml			
Sl. No	Block	Panchayat	Village	Location Details														
1	2	3	4	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	T R Narayan Heritage School, Swami Vivekanand Colony, near Power Sub Station, Mahisauri, Jamui - 811307			Tubewell	7.1	1.8	531	348	165	40	14	44	176	2.68	0.24	NO	T/W	
				RO Plant 1	6.9	1.2	70	46	22	8	2	10	25	0.21	0.018	NO	RO	
2				RO Plant 2	7.5	1.6	34	21	10	4	1	6	12	0.12	0.005	NO	RO	
Desirable Limit*				6.5-8.5	1.00	-	500	200	75	30	250	200.00	45	1.00	YES/NO			
Permissible Limit* in absence of alternate source				NR	5.00	-	2000	600	200	100	1000	600.00	NR	1.5				



PROFORMA REGARDING SANITARY CONDITION CERTIFICATE

Letter No. 1004

Date : 09/04/2026

It is certified that an inspection team headed by SUBHASH SAXENA, Assistant Public Sanitary and Waste Management Officer from Nagar Parishad, Jamui inspected the T R Narayan Heritage School, Jamui Located at Swami Vivekanand Colony, Near Power substation, Mahisauri, Jamui 811307 on 09.04.2026 and found that the T R Narayan Heritage School, Jamui Located at Swami Vivekanand Colony, Near Power substation, Mahisauri, Jamui 811307 has maintaining the safe and hygienic Sanitary condition for the students and members of staff in the school building & the campus as per the norms prescribed by the Central/State/U.TGovt.

The above valid for a period of six months.

Signature with Seal :  कार्यपालक पदाधिकारी

Name : Dr. Priyanka Gupta

Designation : Executive Officer

Name & Address of
the office/Department : Nagar Parishad,
Jamui

To

Principal,
T R Narayan Heritage School,
Swami Vivekanand Colony,
Near Power substation,
Mahisauri, Jamui 811307

Sub
09/04/2026